

Bid Addendum

Contract No.	N/A	Project No.	12669030
Bid Addendum No.	03	Date Issued	August 12, 2026
Owner	McKinleyville Community Services District		
Consultant	GHD		
Project	Highway Sewer Crossing Retrofit		

The purpose of this Addendum is to modify the Contract Documents for the subject project. This Addendum, including attachments, shall become part of said Contract Documents. Each bidder shall acknowledge receipt of this addendum in their bid proposal.

1. The Following Items Provide Changes to the Plans:

None.

2. The Following Items Provide Changes to the Specifications:

None.

3. The Following Items Provide Responses to Bidder Questions:

Item 3.1:

Question: *I was hoping to request the current planholder list for the McKinleyville project, along with anticipated peak/dry-weather flows.*

Response: See attached updated Planholders List. Peak dry and wet weather flows are listed for each manhole on Sheets C-105 and C-106, and in Specification Section 01 55 60, Temporary Bypass Pumping Systems.

Item 3.2:

Question: *I was also curious about the permissible suction manholes, discharge point & bypass duration for the project. After reviewing the plans, I also wanted to ask if we are:*

1. Discharging on one side of the road and picking it pack up on the other?

Putting our discharge pipe through a larger pipeline that runs under the highway? **Response:** Sheets C-105 and C-106 show a proposed construction sequence and bypassing plan including suction and discharge manholes, which is one possible option to maintain sewer flows during the work to be confirmed

by the Contractor. Temporary bypassing is the responsibility of the Contractor and subject to their means and methods, which will dictate the bypass locations and durations. It is not expected that a discharge line would be installed within the highway crossing pipeline to facilitate bypassing as the existing crossing would be used while the new crossing is being installed, as outlined in the proposed construction sequencing.

Item 3.3:

Question: *The other question is, are all bypasses happening simultaneously or are we moving the system around?*

Response: It is expected that some portions of the work will require pumping systems operating simultaneously, which may include pumping on each side of the highway to facilitate installing the replacement manholes. The bypass pumping systems may be moved as necessary throughout the work to facilitate the Contractor's means and methods.

4. The Following Items Provide Clarifications to the Contract:

Item 4.1: See attached updated Planholders List.

Attachments:

1. Planholders List, dated 8/11/2026.

END OF ADDENDUM

Issued By:

GHD

Patrick Sullivan

Print Name



Sign

Date: 8/12/2026

Attachment 1

Planholders List

Planholders List

Contract No.	N/A	Project No.	12669030
Owner	McKinleyville Community Services District		
Consultant	GHD		
Project	Highway Sewer Crossing Retrofit		
Date	August 11, 2026		

Pre-Bid Conference	1:30 P.M. on Wednesday, July 22, 2026, Non-Mandatory
Bid Opening	10:00 A.M. on Friday, August 21, 2026

No	Company Name / Information	Email
1.	Sacramento Builders' Exchange	RCheah@srbx.org
2.	Humboldt Builders' Exchange	hbe-info@humbx.com
3.	North Coast Builders' Exchange	planroom@ncbeonline.com
4.	Shasta Builders' Exchange	planroom@shastabe.com
5.	Medford Builders' Exchange	planroom@medfordbuilders.com
6.	Valley Contractors' Exchange Attn: Elizabeth Carter	Elizabeth@vceonline.com
7.	GR Sundberg Casey Poff, 707-825-6565	grs@grsinc.biz Casey@grsinc.biz ron@grsinc.biz
8.	Wahlund Construction, Inc. Robert W. Crittenden Seamus Frazer, (707)798-0475	Ryan@wahlcon.com bob@wahlcon.com bids@wahlcon.com
9.	Hooven & Co David Hooven, 707-498-3703	david@hoovenco.com
10.	Golden State Boring Jeff Johnson, (909) 930-5811	Jeff@goldenstateboring.com
11.	California Auger Boring Bill Hunt, (714) 204-4972 Zack Poirier	Bill@calaugerboring.com Zack@calboring.com
12.	Allstate Boring Brian Sherrell, 661-399-5000	brian@allstateboring.com
13.	Boring Contractors Tim Cohn, 888-604-6052	tim@boringcontractors.com

No	Company Name / Information	Email
14.	ConstructConnect	Jemar.Sagbigsal@ConstructConnect.com Vince.Sienes@constructconnect.com
15.	Bid Ocean Research	Research@napc.me
16.	Plan Center Northwest	brie@plancenternw.com
17.	McCullough Construction, Inc. Chelsey Rios Curly Carmesin, 707-825-1014	chelseyrios@mcculloughconstructioninc.com
18.	Rain for Rent Fabian Garcia, 530-662-1024	ffgarcia@rainforrent.com
19.	Mercer Fraser Alex Hunt, 707-267-6012	ahunt@mercerfraser.com
20.	Azuria / Underground Solutions Steve Donovan, 541-297-8321	stevedonovan@azuria.com
21.	Herc Rentals Inc. Marty Chayka, 916-781-9481	martin.chayka@hercrentals.com
22.	Xylem Devin Cheong, 916 213 1405	Devin.Cheong@xylem.com
23.	Phoenix Boring Thomas Egan, (415) 919-2809	thomas@phoenixboring.com
24.	K.E.I. Directional Drilling Israel Wafer, 541-643-8301	iwafer@keidirectionaldrilling.com
NOTE: This Planholders List includes only companies that received Contract Documents directly from the Owner or Owner's Representative. This list does not include planholders who received Contract Documents from third-party distributions, such as Builders Exchanges.		